



2006 Water Quality Report

Published in 2007

A Message to Our Consumers

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's **Safe Drinking Water Hotline at (800) 426-4791**.

The Detroit Water and Sewerage Department provides its consumers with high quality water and is honored to provide this report to you. The Water Quality Report gives the sources of our water, lists the results of our tests, and contains important information about water and health. The State and EPA require us to test our water on a regular basis to ensure its safety. As a public utility, we are required to report to our customers annually on the quality of the drinking water we deliver to you. We met all the monitoring and reporting requirements for 2006.

The Detroit Water and Sewerage Department will notify you immediately if there is ever any reason for concern about our water. We are pleased to show you how we have surpassed water quality standards as mandated by the Environmental Protection Agency and the State of Michigan Department of Environmental Quality.

Key to Detected Contaminants Tables

These tables are based on tests conducted by DWSD in the year 2006 or the most recent testing done within the last five calendar years. We conduct many tests throughout the year, however, only tests that show the presence of a substance or required special monitoring are shown here. The table below is a key to the terms used in the tables.

Key to Detected Contaminants Tables		
Symbol	Abbreviation for	Definition/Explanation
MCLG	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
ppb	Parts per billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
ppm	Parts per million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
NTU	Nephelometric Turbidity Units	Measures the cloudiness of water.
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAA5	Haloacetic acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
TTHM	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane, and bromoform. Compliance is based on the total.
n/a	Not applicable	
>	Greater than	

City of Detroit Public Water System

2006 Regulated Detected Contaminants

CONTAMINANT	TEST DATE	UNITS	HEALTH GOAL MCLG	ALLOWED LEVEL MCL	LEVEL DETECTED	RANGE OF DETECTION	VIOLATION YES/NO	MAJOR SOURCES IN DRINKING WATER
Inorganic Chemicals- Annual Monitoring at Plant Finished Tap								
Fluoride	8/15/2006	ppm	4	4	0.974	n/a	No	Erosion of natural deposit; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	8/15/2006	ppm	10	10	0.179	n/a	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Disinfectant Residuals and Disinfection By- Products Monitoring in the Distribution System (Level Detected is the Highest Running Annual Average Based on Quarterly Sampling)								
TTHM	Feb-Nov 2006	ppb	n/a	80	24.9	2.7-45.1	No	By-product of drinking water chlorination.
HAA5	Feb-Nov 2006	ppb	n/a	60	13.9	1.7-24.5	No	By-product of drinking water chlorination.
Disinfectant (Bromate)	Jan-Dec 2006	ppb	0	10	1.1	0.0-0.0	No	By-product of drinking water disinfection.
Disinfectant (Chlorine)	Jan-Dec 2006	ppm	MRDGL 4	MRDL 4	0.73	0.47-0.82	No	Water additive to control microbes.
2006 Turbidity – Monitored every 4 hours at Plant Finished Tap								
HIGHEST SINGLE MEASUREMENT CANNOT EXCEED 1 NTU		LOWEST MONTHLY % OF SAMPLES MEETING TURBIDITY LIMIT OF 0.3 NTU (MINIMUM 95%)				VIOLATION YES/NO	MAJOR SOURCES IN DRINKING WATER	
0.30 NTU		100%				No	Soil Runoff	
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.								
2006 Microbial Contaminants – Monthly Monitoring in the Distribution System								
CONTAMINANT	MCLG	MCL			HIGHEST NUMBER DETECTED	VIOLATION YES/NO	MAJOR SOURCES IN DRINKING WATER	
Total coliform bacteria	0	Presence of coliform bacteria >5% of monthly samples			3.23%	No	Naturally present in the environment	
<i>E. coli</i> or fecal coliform bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive.			0	No	Naturally present in the environment	
2005 Lead and Copper Monitoring at the Customer's Tap								
CONTAMINANT	TEST DATE	UNITS	HEALTH GOAL MCLG	ACTION LEVEL AL	90 TH PERCENTILE VALUE*	NUMBER OF SAMPLES OVER AL	VIOLATION YES/NO	MAJOR SOURCES IN DRINKING WATER
Lead	2005	ppb	0	15	7	2	No	Corrosion of household plumbing system; Erosion of natural deposits; leaching from wood preservatives.
Copper	2005	ppm	1.3	1.3	0.131	0	No	
* The 90 th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90 th percentile value. If the 90 th percentile value is above the AL additional requirements must be met.								
REGULATED CONTAMINANT	TREATMENT TECHNIQUE	RUNNING ANNUAL AVERAGE			MONTHLY RATIO RANGE	VIOLATION YES/NO	TYPICAL SOURCE OF CONTAMINANT	
Total Organic Carbon (ppm)		The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC is measured each quarter and because the level is low, there is no requirement for TOC removal				No	Erosion of natural deposits	
2006 Special Monitoring								
CONTAMINANT	UNITS	MCLG	MCL	LEVEL DETECTED		SOURCE OF CONTAMINATION		
Sodium	ppm	n/a	n/a	5.54		Erosion of natural deposits		

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps the EPA determine where certain contaminants occur and whether it needs to regulate those contaminants.



The Detroit
Water and
Sewerage
Department
wants you
to know
your tap
water meets
or surpasses
all federal
and state
standards
for quality
and safety.

Source Water Assessments

Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from moderately low to very high based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

DWSD has initiated source-water protection activities which include chemical containment, spill response and a mercury reduction program. DWSD participates in a National Pollutant Discharge Elimination System permit discharge program, and has an emergency response management plan. For further information contact the Water Quality Manager at 313-926-8102.

About Lead

Since 1992, with the cooperation of many Detroit residents, DWSD has been testing homes with plumbing systems that may contribute lead to the household water supply. Our 2005 round of testing shows only 2 homes tested have lead levels over the action level. If your home has a lead service line or piping that has lead soldered joints, you can take the following precautions to minimize your exposure to lead that may have leached into your drinking water from your pipes:

- Run your water for 30 to 60 seconds or until it feels colder any time your water has not been used for more than 6 hours.
- Always use cold water for drinking, cooking, or making baby formula.
- Use faucets and plumbing material that are either lead free or will not leach unsafe levels of lead into your water.

Health Effects:

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and could experience learning disabilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.



CITY OF DETROIT

Kwame M. Kilpatrick, *Mayor*

DETROIT CITY COUNCIL

Kenneth V. Cockrel, Jr., *President*
Monica Conyers, *President Pro Tem*
Alberta Tinsley-Talabi
Sheila M. Cockrel
Brenda Jones
Martha Reeves
Kwame Kenyatta
JoAnn Watson
Barbara-Rose Collins

Janice M. Winfrey, *City Clerk*

BOARD OF WATER COMMISSIONERS

Mary E. Blackmon, *President*
Marilynn E. Gosling, *Vice President*
Jimmy L. Cooper
Kenneth R. Daniels
Hilliard L. Hampton
Carla Walker-Miller
William G. Westrick

Victor M. Mercado, *Director*
Gary Fujita, *Deputy Director*

Communities

Served by Detroit Water and Sewerage Department

The Detroit Water and Sewerage Department provides drinking water to approximately 4.3 million people in 126 southeast Michigan communities. The system uses water drawn from three intakes. Two intakes are located in the Detroit River; one to the north near the mouth of Lake St. Clair and one to the south near Lake Erie. The third intake is located in Lake Huron. The Department has five water treatment plants. Four of the plants treat water drawn from the Detroit River intakes. The fifth water treatment plant located in St. Clair County uses water drawn from Lake Huron. Our Detroit customers are provided service from our four plants that treat water drawn from the Detroit River.

Substances

Found in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which are naturally occurring or the result of oil and gas production.

Public Participation

The Board of Water Commissioners meeting is held each month. There are also public hearings and meetings open to the public. To confirm dates and times or for information on other activities happening in the Department, please contact our Public Affairs Division at (313) 964-9570 or visit our Web site www.dwsd.org

ATTENTION!
This is an important report on water quality and safety.
El Informe contiene información importante sobre la calidad del agua en su comunidad.
Por favor, si esta información no es comprensible para usted, solicite a alguien que se la traduzca.



Postal Customer

DWSD'S WATER NAMED BEST-TASTING IN THE STATE
by the American Water Works Association's Michigan Section

PERMITS NO. 7998
DETROIT, MI
U.S. POSTAGE PAID
STANDARD MAIL
PRESORTED

Detroit Water and Sewerage Department
735 Randolph Street
Detroit, Michigan 48226

About Water

The DWSD Speakers Bureau provides an invaluable, face-to-face opportunity for school students, community groups and others to learn about the quality and production of Detroit's drinking water. To schedule a speaker, call the Public Affairs Division at **(313) 964-9570**.

Health Concerns

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA and Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline, **(800) 426-4791**.

Emergency

To report emergencies, such as flooded streets and basements, missing manhole covers or water main breaks. 24-Hour Number: **(313) 267-7401**



This report is available on our Web site at www.dwsd.org.

We welcome your comments and opinions about this report and will be happy to answer any questions you may have. Please direct your comments or questions to the

Public Affairs Division at:
(313) 964-9570
or you may email your comments to:
public.affairs@dwsd.org